



**DECO PATH – SECTION**

GRASS/TURF.  
 EDGE AS SPECIFIED. FOR TIMBER EDGE, REFER UMS 747 WALKING TRACK.  
 100mm DEPTH STABILISED DECOMPOSED GRANITE PAVEMENT AS SPECIFIED.  
 COMPACTED SUBBASE TO 95% MOD. M.D.D.  
 COMPACTED SUB-GRADE TO 100% STANDARD M.D.D.  
 EDGE AS SPECIFIED. FOR PAVER EDGE, USE 115x230x50mm STRETCHERBOND PAVER COURSE SET ON A CONCRETE HAUNCH.  
 FINISH MULCH 25mm BELOW PAVER F.S.L.

**GENERAL NOTES**

ENSURE MOWN HEIGHT OF GRASS (TURF) FINISHES FLUSH WITH PATH EDGE.  
 ENSURE GARDEN AREAS (MULCH) FINISH 25mm BELOW ADJACENT PATH EDGE.  
 ENSURE EVEN GRADE CROSSFALL MIN. 1:50 TO PATH.  
 ENSURE PATHS, TRACKS AND TRAILS ARE LOCATED AND LANDSCAPED IN ACCORDANCE WITH DETAILED LANDSCAPE PLAN, AND SUBDIVISION AND DEVELOPMENT GUIDELINES.  
 ALL DIMENSIONS IN MILLIMETRES (U.N.O.).

**GENERAL NOTES**

**COMPACTION**  
 COMPACT SUBBASE AND DECO MATERIAL SEPARATELY NOT LESS THAN 95% MAXIMUM DRY DENSITY AS DETERMINED BY THE MODIFIED COMPACTION TEST AS DEFINED IN AS 1289.1977 FOR THE UPPER 150mm. AVOID COMPACTION AROUND THE BASE OF EXISTING AND PROPOSED TREES.

**SUBBASE PREPARATION**  
 ENSURE SUBBASE PROFILE FORMS THE REQUIRED DRAINAGE FALLS WHEN THE SURFACE IS LAID.

**SURFACE CONSTRUCTION**  
 THE FOLLOWING STEPS ARE SUGGESTED AND WILL NEED TO BE REPEATED TO ACHIEVE THE F.S.L:  
 1- PLACE AND RAKE EVENLY APPROXIMATELY 30mm OF DECOMPOSED GRANITE MATERIAL.  
 2- ADD DUSTAC (OR APPROVED EQUIVALENT) AT A RATE RECOMMENDED BY MANUFACTURER.  
 3- MOISTEN THE MATERIAL AND COMPACT USING A VIBRATING ROLLER. THE ROLLER SHOULD NOT WEIGH MORE THAN 30KG.

THE FINISHED SURFACE SHALL BE FREE FROM STONES EXCEEDING 20mm IN DIAMETER AND SHALL REMAIN FREE OF RUTS, SUBSIDENCE AND LACK OF COHESION.

IF AT TIME OF CONSTRUCTION, THE SUB-GRADE STRENGTH IS SUCH THAT IT IS PENETRATING / INFILTRATING THE CLASS 2 GRAVEL LAYER DURING COMPACTION, A B.C.C. TYPE 3 GEOTEXTILE IS TO BE PLACED BETWEEN THE GRAVEL AND THE SUB-GRADE

ISSUE	AMENDMENT	DRAWN DATE	CHK'D DATE	APPR'D DATE
A	ORIGINAL ISSUE	Dec '03	Jul '14	PC 19/04

DESIGN AUTHORISED FOR ISSUE PAUL COTTON SIGNATURE ON ORIGINAL DATED 13/10/14	DESIGN APPROVED R.B.E.O. 2516	DESIGN APPROVED LAREN TEMPLEMAN SIGNATURE ON ORIGINAL DATED 31/08/14	DESIGN APPROVED CITY DESIGN - L.A.	DATE Dec '03
MANAGER INFRASTRUCTURE MANAGEMENT R.B.E.O. 2516	CHECKED UHS 744dmg	DRAWING UHS 744dmg	CITY DESIGN - L.A.	DATE Jun '04
PRINCIPAL PROGRAM OFFICER PARKS	ASSOCIATED PLANS			



**BRISBANE CITY COUNCIL - URBAN MANAGEMENT DIVISION**

**PATH – DECO**

SCALE 1:10	TITLE <b>UMS 744</b>	REVISION A
ORIGINAL SIZE A3		