


WALKING TRACK - SECTION



WALKING TRACK - PLAN

LANDSCAPE AS SPECIFIED.

100x15mm EDGE TIMBER NAIL FIXED TO STAKES. ENSURE PATH AND OTHER SURFACES FINISH FLUSH WITH EDGE.

GRADE EXISTING EARTH AND COMPACT TO 100% STANDARD M.D.D.

75x15x400mm JOINDER TIMBER GALV. NAIL FIXED TO EDGE TIMBER.
50x50x450mm STAKES AT 1750mm CCS MAX.

WIDTH VARIES

COMPACTED EXISTING EARTH

75x15x400mm JOINDER TIMBER FOR SECURING 100x15mm EDGING TIMBERS.

GENERAL NOTES

- ENSURE MOWN HEIGHT OF GRASS (TURF) AREA FINISHES FLUSH WITH WALKING TRACK EDGE.
- ENSURE GARDEN AREAS (MULCH) AND NATURAL VEGETATION AREAS FINISH 25mm BELOW ADJACENT F.S.L.'s OF WALKING TRACK.
- ENSURE EVEN GRADE CROSS-FALLS MIN. 1:50 TO WALKING TRACKS.
- ENSURE WALKING TRACK ARE LOCATED AND CONSTRUCTED IN ACCORDANCE WITH DETAILED LANDSCAPE PLAN, AND SUBDIVISION AND DEVELOPMENT GUIDELINES.
- ALL DIMENSIONS IN MILLIMETRES (U.N.O.).

TIMBER NOTES

- ALL TIMBER TO BE ACQ TREATED ROUGH SAWN APPEARANCE GRADE HARDWOOD OF A SINGLE SPECIES.
- ALL TIMBER TO BE PRESERVATIVE TREATED TO HAZARD CLASS H5 TO AS 1604.1-2000 AND HAVE A DURABILITY CLASS 1 OR 2 TO AS 5604-2003.
- ALL TIMBER TO BE FREE OF KNOTS, SPLINTERS, CRACKS OR ANY MAJOR DEFECT.
- LOCATE TIMBER EDGE AS NOTED ON PLAN.
- FIX EDGE WITH 2 (MIN.) NAILS PER STAKE.
- TO FORM CURVES SAW CUT RELIEF TO EDGE TO PROMOTE EASE OF BENDING. STAKE AT CLOSER CENTRES WHERE REQUIRED.

ISSUE	AMENDMENT	DRAWN DATE	CHK'D DATE	APPR'D DATE
A	ORIGINAL ISSUE	Dec '03	Jul '14	PC 19/04

DESIGN AUTHORISED FOR ISSUE
PAUL COITON SIGNATURE ON ORIGINAL
DATED 13/07/14

MANAGER INFRASTRUCTURE MANAGEMENT
R.P.E.O. 2516

DESIGN APPROVED
LAVEN TEMPLEMAN SIGNATURE ON ORIGINAL
DATED 31/08/14

PRINCIPAL PROGRAM OFFICER PARKS

DESIGN	CITY DESIGN - L.A.	DATE	Dec '03
DRAWN	CITY DESIGN - L.A.	DATE	Dec '03
CHECKED	UHS - E.P.J.J.I and H.B. D.L. & G.M.I.	DATE	Jun '04
DRAWING FILENAME	UHS 747.dwg		
ASSOCIATED PLANS			



BRISBANE CITY COUNCIL - URBAN MANAGEMENT DIVISION

WALKING TRACK

SCALE	1:10
TITLE	UHS 747
ORIGINAL SIZE	A3
REVISION	A